

Consultee Comments for Planning Application APP/25/00101

Application Summary

Application Number: APP/25/00101

Address: Prince of Wales, 164 West Street, Havant, PO9 1LR

Proposal: Display of illuminated and non-illuminated signs to the exterior of the building |cr|Sign A - 1No new pictorial to existing wall bracket and new linolites |cr|Sign B - 2No refurbish the existing masonry housename and symbols |cr|Sign C - 1No new a1 poster case |cr|Sign D - 1No new brass portland lantern |cr|Sign E - 5No new led floodlights |cr|Sign F - 1No new amenity sign/chalkboard |cr|Sign G - 2No new trough lights |cr|Sign H - 1No new brass lantern on bow bracket

Case Officer: Denise Sheath

Consultee Details

Name: Consultee Environmental Health (Environment Team)

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: Not Available

On Behalf Of: Environmental Health Manager, Community Group

Comments

Thank you for consulting the Environmental Protection Team on this application. Although we have no objection to the proposal, we note that the level of proposed lighting appears to be quite significant, with seemingly no other purpose than to illuminate the building itself. The level of proposed lighting could lead to artificial light nuisance complaints due to the glare of the light, which could be acerbated by the colour of the existing render on the building itself, and the fact that the colour of the proposed lighting looks to be very cool. The situation could be improved by reducing the amount of lighting and adjusting the colour of the lights to make them warmer. I also note that the premises is within a Conservation Area, which may affect the acceptability of the proposal.

Regards

Helen Le-Vallee

Environmental Health Officer

Environmental Protection Team

Havant Borough Council