



Havant Borough Council
Public Service Plaza
Civic Centre
Havant
Hampshire
PO9 2AX

Your ref
APP/23/00928

Our ref
DSA000035498

Date
01/08/2024

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Havant College, Barncroft Way, Havant, PO9 1QL

Site: Erection of new three storey teaching building and provision of 8No. additional parking spaces, 14No. cycle spaces, new fencing and landscaping. (20.06.24). Request to discharge conditions 10, 11 and 12 (21.06.24).

Thank you for your correspondence dated 27/06/2024 regarding the above planning application. Please see our comments below.

Unfortunately, we are unable to comment on the proposal, as the plans provided are insufficient. This development requires a capacity check as a foul pumping station is proposed. To be able to complete this capacity check, we require the foul Litres per second amount and the total number of units.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development