

Mrs J Carrington
Foreman Homes Ltd
Yarmouth House
1300 Parkway
Whiteley
PO15 7AX

Our Ref: APP/18/01109
Direct Line: (023) 07771 378359
Ask For: Ms L Wells
Email: planning.development@havant.gov.uk
19 December 2024

**Town and Country Planning (Development Management Procedure) (England) Order 2015
Discharge of Conditions Application**

Application Number: APP/18/01109

Site Address: Dairy Crest Depot, Dunsbury Way, Havant

Description: Outline application for the redevelopment of Former Dairy Crest site for up to 74 dwellings with access off Fulflood Road (31.3.21). Request to discharge condition 4 (recd 24.11.22). Request to discharge condition 9 (31.1.23). Request to discharge conditions 10 and 11. (12.06.24). Request to discharge conditions 5 & 7 (06.09.24).

This decision relates to your request to discharge conditions which was valid from 06 September 2024.

Havant Borough Council as Local Planning Authority hereby APPROVES the submitted application as meeting the information requirements of the following Conditions of Planning Permission APP/18/01109.

The conditions in respect of which information has been submitted are:

Condition 7:

No piling shall take place until a piling method statement (detailing the depth and type of piling to be undertaken and the methodology by which such piling will be carried out, including measures to prevent and minimise the potential for damage to subsurface water infrastructure, vibration and the programme for the works) has been submitted to and approved in writing by the Local Planning Authority in consultation with the Environment Agency and Portsmouth Water. Any piling, if proposed, must be undertaken in accordance with the terms of the approved piling method statement.

Reason: Piling or any other foundation designs using penetrative methods can pose a risk to potable supplies from, for example, turbidity, mobilisation of historical contaminants, drilling through different aquifers and creation of preferential pathways. Therefore, penetrative foundation methods have the potential to impact on the underlying groundwater and thus the Havant and Bedhampton Springs public water supply. This condition is therefore necessary having due regard to policies and proposals CS16 and DM10 of the Havant Borough Local Plan (Core Strategy) 2011 and the National Planning Policy Framework.

Details submitted:

Condition 11:

The development hereby permitted shall not be occupied until:

- (a) A water efficiency calculation in accordance with the Government's National Calculation Methodology for assessing water efficiency in new dwellings has been undertaken which demonstrates that no more than 110 litres of water per person per day shall be consumed within the development, and this calculation has been submitted to, and approved in writing by, the Local Planning Authority; and
- (b) All measures necessary to meet the approved water efficiency calculation have been installed.

Reason: There is existing evidence of high levels of nitrogen and phosphorus in the water environment with evidence of eutrophication at some European designated nature conservation sites in the Solent catchment. The PUSH Integrated Water Management Strategy has identified that there is uncertainty as to whether new housing development can be accommodated without having a detrimental impact on the designated sites within the Solent. Further detail regarding this can be found in the appropriate assessment that was carried out regarding this planning application. To ensure that the proposal may proceed as sustainable development, there is a duty upon the local planning authority to ensure that sufficient mitigation is provided against any impacts which might arise upon the designated sites. In coming to this decision, the Council have had regard to Regulation 63 of the Conservation of Habitats and Species Regulations 2017, Policy CS11 of the Havant Borough Local Plan (Core Strategy) 2011, and Policy E14, EX1 and E12 of the Pre-Submission Havant Borough Local Plan.

Details submitted:

Breakdown of Water Calculations

Reasons for approval

The details hereby approved are considered to be in accordance with the relevant adopted policies of the Council, in particular the policies contained within the Havant Borough Local Plan (Core Strategy) 2011.

- (1) This notice only relates to the decision of Havant Borough Council as Local Planning Authority under the Town and Country Planning Acts. It does not relate to any other application that may be required under the Building Regulations or under any other Act, Regulation, Byelaw or Order where the Council's approval may be needed. For further guidance as to the need for consent under the Building Regulations please phone 023 9244 6573.
- (2) Any failure to adhere to the details of the approved plans, and other documents or to comply with any conditions listed above may lead to enforcement action being taken by the Council. If you wish to depart from the approved details or conditions in any way you should contact the Planning Development Service at the Public Service Plaza or by telephoning 023 9244 6015.

Alex Robinson

Alex Robinson
Executive Head of Place
Date: 19 December 2024