

Further to the receipt of the water calculations submitted which you emailed me about on the 27th Dec in respect of App 22/01134 Land Adjacent to 41 Sinah Lane, Hayling Island, I can confirm that having assessed the information provided it appears to meet Part A of condition 5, namely "A water efficiency calculation in accordance with the Government's National Calculation Methodology for assessing water efficiency in new dwellings has been undertaken which demonstrates that no more than 110 litres of water per person per day shall be consumed within the development." Part B of the condition will need to be assessed once the development is built and fittings are installed.

Regards

Robin Seamer BSc (Hons) MRICS MCMI
Building Control Manager

East Hampshire District Council, Penns Place, Petersfield