



APP/24/00341 - Unit 3, 3 Station Road, Hayling Island

From Moss, Mark <Mark.Moss@havant.gov.uk>
Date Mon 30-Sep-24 5:24 PM
To Riley, Robert <Robert.Riley@havant.gov.uk>

Good day Robert

It has been noted from the updated supporting statement, that the applicant now intends to also grill & deep fry in this kitchen, besides pizza preparation.

Based on the above, I will provide an update to my previous comments below:

I would query whether the applicant has considered, besides the standard bar grease filters in the canopy, the addition of a fine or pre-filtration system in addition & prior to the carbon filters.

I would further suggest that if this application were to be approved, that the applicant ensures that in addition to my previously advised Condition 3, that it be clarified with the supplier that the extraction system will meet the following criteria:

The rating level of any plant, equipment & / or operational noise, as part of the extraction unit, will be at least 5 dB below the existing background levels. The assessment must be in accordance with BS4142: 2014 Methods for rating and assessing industrial and commercial sound. Background levels shall need to be established at nearest residential receptors.

The applicant will also need to clarify the exact silencer to be used in order to understand the expected dB reduction levels to be achieved.

Please contact me should you have any queries in regard to the above.

Regards

Mark Moss

Regulatory Officer
Environmental Health Pollution team
Havant Borough Council
Direct Tel: 02392 – 446666
E-mail: mark.moss@havant.gov.uk

www.havant.gov.uk

www.facebook.com/havantboroughcouncil

www.twitter.com/havantborough

Your privacy matters, go to www.havant.gov.uk/privacy-policy

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient please notify the sender and delete the message from your system immediately.