

Planning Application APP/19/01226 Land west of Coldharbour Farm Road, Emsworth

Thank you for consulting us on the surface water drainage and SuDS maintenance details.

The proposals have changed to combine the attenuation storage for the private and road drainage. This has altered how the attenuation storage is set out and changed the flow control requirements. Updated calculations should be submitted to show that the system will work in a similar way to that previously agreed.

Regards

Tom Callaway

Senior Flood and Water Management Project Officer

Flood and Water Management

thomas.callaway@hants.gov.uk

www.hants.gov.uk