



Your ref
APP/24/00939

Our ref
DSA000040006

Date
03/06/2025

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Reserved matters application comprising 185 residential dwellings, associated amenity space, access, garages, parking, internal roads, pathways and associated landscaping (matters of layout, appearance, access, landscape and scale) pursuant to application ref APP/10/00828 (and WCC application 10/02862/OUT).

Site Address: Berewood Phase 8 Development Site, London Road, Waterlooville.

Southern Water have reassessed capacity to determine that there is capacity available for 0.61 l/s at the proposed

New Foul Water Sewer at the 200 VC in London Road (Grid Reference: 467828 , 10892). There is currently adequate capacity in the local sewerage network to accommodate a foul flow of 0.61 l/s for the above development at the proposed New Foul Water Sewer at the 200 VC in London Road.

Southern Water recommends no objection to this development.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development