

Bellamy Roberts					Page 1
Clover House Western Lane Odiham RG29 1TU		Premier Coastal Properties Ltd Warblington Road, Emsworth Storage Tank 2			
Date 02/01/2024 10:56 File STORAGE AREA 2.SRCX		Designed by JCB Checked by MT			
Innovyze		Source Control 2020.1.3			
<u>Summary of Results for 30 year Return Period (+35%)</u>					
Storm Event	Max Level (m)	Max Depth (m)	Max Control (l/s)	Max Volume (m³)	Status
15 min Summer	4.138	0.438	2.2	17.5	O K
30 min Summer	4.257	0.557	2.4	22.3	O K
60 min Summer	4.350	0.650	2.7	26.0	O K
120 min Summer	4.399	0.699	2.8	27.9	O K
180 min Summer	4.408	0.708	2.8	28.3	O K
240 min Summer	4.401	0.701	2.8	28.0	O K
360 min Summer	4.372	0.672	2.7	26.9	O K
480 min Summer	4.336	0.636	2.6	25.5	O K
600 min Summer	4.301	0.601	2.5	24.0	O K
720 min Summer	4.267	0.567	2.5	22.7	O K
960 min Summer	4.207	0.507	2.3	20.3	O K
1440 min Summer	4.112	0.412	2.1	16.5	O K
2160 min Summer	4.015	0.315	1.8	12.6	O K
2880 min Summer	3.950	0.250	1.6	10.0	O K
4320 min Summer	3.872	0.172	1.3	6.9	O K
5760 min Summer	3.828	0.128	1.1	5.1	O K
7200 min Summer	3.802	0.102	1.0	4.1	O K
8640 min Summer	3.785	0.085	0.8	3.4	O K
10080 min Summer	3.772	0.072	0.8	2.9	O K
15 min Winter	4.192	0.492	2.3	19.7	O K
30 min Winter	4.328	0.628	2.6	25.1	O K
Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)	
15 min Summer	93.966	0.0	18.8	18	
30 min Summer	62.553	0.0	25.0	32	
60 min Summer	39.897	0.0	32.0	60	
120 min Summer	24.703	0.0	39.6	94	
180 min Summer	18.451	0.0	44.4	128	
240 min Summer	14.924	0.0	47.9	162	
360 min Summer	11.048	0.0	53.2	230	
480 min Summer	8.918	0.0	57.2	298	
600 min Summer	7.549	0.0	60.5	366	
720 min Summer	6.585	0.0	63.4	432	
960 min Summer	5.304	0.0	68.1	558	
1440 min Summer	3.905	0.0	75.2	808	
2160 min Summer	2.871	0.0	82.9	1168	
2880 min Summer	2.306	0.0	88.8	1528	
4320 min Summer	1.692	0.0	97.7	2248	
5760 min Summer	1.357	0.0	104.5	2944	
7200 min Summer	1.143	0.0	110.0	3672	
8640 min Summer	0.994	0.0	114.8	4408	
10080 min Summer	0.883	0.0	119.0	5136	
15 min Winter	93.966	0.0	21.0	18	
30 min Winter	62.553	0.0	28.0	32	
©1982-2020 Innovyze					

Bellamy Roberts					Page 2
Clover House Western Lane Odiham RG29 1TU		Premier Coastal Properties Ltd Warblington Road, Emsworth Storage Tank 2			
Date 02/01/2024 10:56 File STORAGE AREA 2.SRCX		Designed by JCB Checked by MT			
Innovyze		Source Control 2020.1.3			
<u>Summary of Results for 30 year Return Period (+35%)</u>					
Storm Event	Max Level (m)	Max Depth (m)	Max Control (l/s)	Max Volume (m³)	Status
60 min Winter	4.439	0.739	2.8	29.6	O K
120 min Winter	4.492	0.792	2.9	31.7	O K
180 min Winter	4.498	0.798	2.9	31.9	O K
240 min Winter	4.482	0.782	2.9	31.3	O K
360 min Winter	4.432	0.732	2.8	29.3	O K
480 min Winter	4.376	0.676	2.7	27.1	O K
600 min Winter	4.323	0.623	2.6	24.9	O K
720 min Winter	4.273	0.573	2.5	22.9	O K
960 min Winter	4.189	0.489	2.3	19.5	O K
1440 min Winter	4.065	0.365	2.0	14.6	O K
2160 min Winter	3.951	0.251	1.6	10.1	O K
2880 min Winter	3.885	0.185	1.4	7.4	O K
4320 min Winter	3.817	0.117	1.0	4.7	O K
5760 min Winter	3.784	0.084	0.8	3.4	O K
7200 min Winter	3.766	0.066	0.7	2.6	O K
8640 min Winter	3.756	0.056	0.6	2.2	O K
10080 min Winter	3.752	0.052	0.6	2.1	O K
Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)	
60 min Winter	39.897	0.0	35.8	60	
120 min Winter	24.703	0.0	44.4	98	
180 min Winter	18.451	0.0	49.7	136	
240 min Winter	14.924	0.0	53.6	174	
360 min Winter	11.048	0.0	59.5	250	
480 min Winter	8.918	0.0	64.1	320	
600 min Winter	7.549	0.0	67.8	390	
720 min Winter	6.585	0.0	71.0	456	
960 min Winter	5.304	0.0	76.2	588	
1440 min Winter	3.905	0.0	84.2	838	
2160 min Winter	2.871	0.0	92.9	1208	
2880 min Winter	2.306	0.0	99.5	1556	
4320 min Winter	1.692	0.0	109.4	2252	
5760 min Winter	1.357	0.0	117.0	2944	
7200 min Winter	1.143	0.0	123.2	3672	
8640 min Winter	0.994	0.0	128.6	4392	
10080 min Winter	0.883	0.0	133.3	5128	
©1982-2020 Innovyze					

Bellamy Roberts		Page 3
Clover House Western Lane Odiham RG29 1TU	Premier Coastal Properties Ltd Warblington Road, Emsworth Storage Tank 2	
Date 02/01/2024 10:56 File STORAGE AREA 2.SRCX	Designed by JCB Checked by MT	
Innovyze	Source Control 2020.1.3	
<		

Bellamy Roberts		Page 4												
Clover House Western Lane Odiham RG29 1TU	Premier Coastal Properties Ltd Warblington Road, Emsworth Storage Tank 2													
Date 02/01/2024 10:56 File STORAGE AREA 2.SRCX	Designed by JCB Checked by MT													
Innovyze		Source Control 2020.1.3												
Model Details Storage is Online Cover Level (m) 5.500 Tank or Pond Structure Invert Level (m) 3.700 <table><thead><tr><th>Depth (m)</th><th>Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th></tr></thead><tbody><tr><td>0.000</td><td>40.0</td><td>1.200</td><td>40.0</td><td>1.201</td><td>0.0</td></tr></tbody></table> Orifice Outflow Control Diameter (m) 0.040 Discharge Coefficient 0.600 Invert Level (m) 3.700			Depth (m)	Area (m²)	Depth (m)	Area (m²)	Depth (m)	Area (m²)	0.000	40.0	1.200	40.0	1.201	0.0
Depth (m)	Area (m²)	Depth (m)	Area (m²)	Depth (m)	Area (m²)									
0.000	40.0	1.200	40.0	1.201	0.0									
©1982-2020 Innovyze														