



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/23/00692

Our ref
DSA000029960

Date
03 January 2024

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Single storey rear extension, relocation of side gate and enlargement of side window (Approved 9.11.2023). Request to Discharge Condition 4 (7.12.2023).

Site: APP/23/00692: - 16 Morley Crescent, Waterlooville, PO8 8JG.

Thank you for your letter dated 13 December 2023.

Southern Water cannot recommend discharge of condition 04 related to protecting of public sewers. The submitted existing and proposed sewer layout (Drawing no- 3 REV-A) shows that the building lies close to an existing public foul sewer which is not acceptable to Southern Water.

We request that the developer submit an application under the build-over process, where the proposed measures to protect the sewer will be reviewed. The conditions and application associated with the build-over a public sewer are available at Southern Water's Get Connected service: Southern Water's Get Connected service: developerservices.southernwater.co.uk

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development