



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/22/00669

Our ref
DSA000030023

Date
17 January 2024

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Outline planning application with all matters reserved (except for access) for the development of up to 120 residential dwellings (C3 Use), with access from Meyrick Road, the provision of open space, landscaping and other associated works including demolition of existing buildings on site.

Site: APP/22/00669: - Land at Kingscroft Farm adjacent to Ridgway and, Marples Way, Havant, PO9 1QJ.

Thank you for your letter dated 02 January 2024.

In determining the application, we ask that the Planning Authority take into account the provisions of Paragraphs 180, 182 and 183 of the National Planning Policy Framework (NPPF) regarding the proposed location of development in relation to existing uses that may be a source of pollution (in terms of odour). We apply a precautionary buffer zone for any development located within 500 metres of the boundary of a WWTW. The proposed development is located approximately 430 metres from the Budds Farm Havant Wastewater Treatment Works, and as such we have applied this requirement to our planning consultation response. Please contact Southern Water to discuss and agree the Scope of the odour assessment.

Due to the potential odour nuisance from a Wastewater Treatment Works, no sensitive development should be located within the 1.5 OdU odour contour of the WWTW. An Odour Assessment will need to be carried out by a specialist consultant employed by the developer to a specification that will need to be agreed in advance with Southern Water to identify and agree the 1.5 OdU contour. The service we provide to review the assessment and/or complete a site survey is chargeable, more information regarding our fees can be found on our website; Connection charging arrangements (southernwater.co.uk).

All other comments in our response dated 19 September 2023 remain unchanged and valid.



For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development