

Thank you for consulting us on this application.

In our previous response dated 16th August 24, we requested details of water treatment which needed to be presented in line with the SuDS Manual simple index approach. This has not been provided and the reliance on trapped gullies is not considered a suitable form of water treatment.

As such, our previous response can still be considered valid

Regards
Sarah

Sarah Reghif
Flood and Water Management - Technical

Universal Services
Hampshire County Council
The Castle
Winchester
Hampshire
SO23 8UD

[E-mail: SWM.consultee@hants.gov.uk](mailto:SWM.consultee@hants.gov.uk)