



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/22/00439

Our ref
DSA000025213

Date
25/07/2023

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Redevelopment of southern section of site to provide 102 dwellings comprising 56 No. 2, 3 & 4 bed houses and 46 No. 1 & 2 bed flats with associated parking, landscaping, waste and cycle storage. New roundabout access from College Road.

Site: APP/22/00439: - The South Downs College, College Road, Purbrook, Waterlooville, PO7 8AA.

Thank you for your letter dated 04/07/2023.

The Submitted drainage layout (Drawing no: 01-PDL-1001, REV:C) information shows that the applicant is discharging surface water flow no greater than existing flows into the public system, ensuring no overall increase in flows into the sewerage system, which is acceptable to Southern Water.

All other comments in our response dated 27/06/2022 remain unchanged and valid.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development