

23 October 2023



Seacourt Tennis Club
20 Vicotria Avenue
Hayling Island
PO11 9AJ

73 Westman Road
Winchester
Hampshire
SO22 6DX

01962 461016
0203 8650332

VA4834 Seacourt Tennis Club, Hayling Island

Proposed Padel Court Mitigation

Following our Noise Impact Assessment Report (4834.230817.NIA, 17 August 2023) of the proposed new padel courts at Seacourt Tennis Club, comment has been received from Havant Council Environmental Health (19th October 2023) requesting specific details of the screening be provided in accordance with the previous consultation response of 4th August 2023. The previous consultation recommended the following conditions:

"Before the permitted development comes into use, a fence or barrier having a superficial weight not less than 10kg/m² with a height of not less than 1.8 meters shall be erected and thereafter permanently maintained around the perimeter of the site facing any residential property."

The current acoustic report includes the following recommendations for mitigation in section 5.2:

"To control sound transmission to the residential elements to the north and south of the site, it is recommended that imperforate screening fences, with a minimum superficial density of 13kg/m², are located to the north and south of the courts. Due to the existing trees, the height of the screens is limited to 2m. The predicted sound levels have been calculated with these mitigation measures in place"

The attached image shows the proposed location of these fences.

With this mitigation in place, a low noise impact is expected from the scheme as detailed in the Noise Assessment Report.


We trust that this provides the required information. Please do not hesitate to contact us with any questions.

Yours sincerely

on behalf of Venta Acoustics

Steven Liddell

email: sliddell@ventaacoustics.com



Acoustic Screens
Height: 2m
Density: 13kg/m²

