



Registered Office:
Portsmouth Water Ltd
PO Box 8
Havant
Hampshire PO9 1LG

Tel: 023 9249 9888
Fax: 023 9245 3632
Web: www.portsmouthwater.co.uk

**CONSULTATION UNDER THE TOWN AND COUNTRY PLANNING
(DEVELOPMENT MANAGEMENT PROCEDURE ENGLAND) ORDER 2010**

Planning Application Reference:	APP/23/00829
Proposal:	Erection of 1No. 4bed house on land belonging to no 34 Pennant Hills
Location:	34 Pennant Hills, Havant, PO9 3JZ
Date:	06 December 2023

Thank you for consulting Portsmouth Water on the application for 1.No 4 bed house, Pennant Hills, Havant. The Catchment Management Team have reviewed the relevant documentation and have the following comments.

Portsmouth Water's Position

The proposed site is located within Source Protection Zone SPZ1 for the Havant and Bedhampton Springs. The geology beneath the setting is classified as a principal aquifer, the groundwater area is of high sensitivity and consequently all measures to prevent pollution during and post construction are required in order to safeguard the local public water supply source.

Our records show that the depth to groundwater at this location is relatively shallow. We therefore wish to see more detail on the drainage design and foundations for the site.

Catchment Management Team
Portsmouth Water

catchment.management@portsmouthwater.co.uk