

Consultee Comments for Planning Application APP/23/00910

Application Summary

Application Number: APP/23/00910

Address: 52 Creek Road, Hayling Island, PO11 9RE

Proposal: Revised siting of condensers (retrospective).

Case Officer: Denise Sheath

Consultee Details

Name: Consultee Environmental Health (Environment Team)

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: Not Available

On Behalf Of: Environmental Health Manager, Community Group

Comments

Thank you for consulting the Council's Environmental Protection Team on this application. The proposed acoustic enclosures should ensure that noise from the condensers does not give rise to impact on amenity at nearby residential dwellings. However, we recommend the following condition is attached,

- The noise from the condensers which are subject to this application shall be covered with acoustic enclosures which mitigate the noise in accordance with the information supplied in the acoustic report submitted by SoundAdvice dated 11.09.2023 (Ref. SAE-1157 Issue 1)., specifically the data provided under the heading 'Acoustic Enclosure Performance'.

Regards

Helen Le-Vallee

Environmental Health Officer

Havant Borough Council