

HAVANT BOROUGH COUNCIL

Town & Country Planning Act 1990

Consultation on Planning Application

MEMORANDUM

From:	Environmental Health	To:	Development Control
Our Ref:	CONS/23/02709	Your Ref:	APP/23/00328
EH Case Officer Extn:	44 6666	Date:	19 September 2023
DC Case Officer:	Ms Ikrame Essalih		
DC Case Officer Extn:			
Application Number:	APP/23/00328		
Site Address:	54A Stakes Hill Road, Waterloooville, PO7 7LB		
Proposed Development:	Installation of 1No. external air conditioning unit.		
	RECONSULTATION REQUEST for revised documents received		
	Our Ref:APP/23/00328		

Observations / Comments:

I refer to the above application under the Town & Country Planning Acts passed to this Service for comment.

I have perused the additional noise impact assessment report now submitted. This report advises that the predicted sound levels at the two nearest noise sensitive properties, are below the representative background noise levels during the day.

It has been advised previously by the applicants representative that the unit will only be operated during the following hours and mainly during the summer months:

Monday to Friday:	08:30 - 18:30
Saturday:	08:30 - 12:30
Sunday:	Premises closed.

Therefore, if consent were to be granted on this application, I would ask that the above times of operation of this unit, be conditioned as such.

Mr. Mark Moss
Regulatory Officer, Environmental Health