

Sound Insulation Condition A scheme of noise insulation/reduction shall be submitted to ensure that the noise level of 35 dBLAeq, 16 hour in living rooms and bedrooms during the daytime (0700 to 2300 hours) and 30 dBLAeq, 8 hour and 45 dBLAmax during the night-time (measured with F time-weighting and between 2300 and 0700 hours) in bedrooms in accordance with BS8233:2014 shall not be exceeded. Where these levels cannot be met with windows open appropriate acoustic ventilation should be provided so that the room can be sufficiently ventilated. The acoustic performance of any passive vent, variable speed mechanical air supply unit or whole house ventilation must be sufficient to ensure that the noise level standards given above are not compromised.

Reason: *To ensure the residential amenity of the properties is not impacted upon by any external noise levels, especially traffic noise having due regard to policy CS16 of the Havant Borough Local Plan (Core Strategy) 2011 and the National Planning Policy Framework.*

Regards

Chima Umunnakwe

Interim Pollution Team Leader / Planning Apps | T: 02392446397 : Mobile 07827070743

Environmental Health

Havant Borough Council, Public Service Plaza, Havant, PO9 2AX