



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/23/00004

Our ref
DSA000024395

Date
21/06/2023

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Temporary use of land to carry out ground investigation works comprising the drilling of 2 no. boreholes and the installation of headworks and equipment to monitor ground conditions for a period of 18 months including mobilisation, decommissioning and full restoration periods.

Site: APP/23/00004: - Pavilion, Bidbury Lane, Havant, PO9 3JJ.

Thank you for your letter dated 08/06/2023.

Further to our response dated 07/04/2023 and the amended details submitted, Southern Water has the following comments to make:

The submitted site layout (Dwg No. 760010-BH101&BH102-03) indicating a clearance of 3.935 metres between BH102 and the 525 mm public foul sewer, is satisfactory to Southern Water.

Please note: All existing infrastructure should be protected during the course of works.

All other comments in our response dated 07/04/2023 remains unchanged and valid.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development