

Dear David

Further to the receipt of the water calculations submitted which you emailed me about on the 25th Jan in respect of APP/18/00109 Land adj 15 Billett Avenue, Waterlooville, PO7 7SZ I can confirm that having assessed the information provided it appears to meet Part A of condition 14, namely "A water efficiency calculation in accordance with the Government's National Calculation Methodology for assessing water efficiency in new dwellings has been undertaken which demonstrates that no more than 110 litres of water per person per day shall be consumed within the development." I have assumed that this calculation covers all plots on the development.

Part B of the condition will need to be assessed once the development is built and fittings are installed. I would suggest if once built the developer confirms the build has been done as per the specification for the water fittings / calculator, this would be enough to satisfy Part B.

Regards

Robin Seamer BSc (Hons) MRICS MCMI
Building Control Manager

East Hampshire District Council, Penns Place, Petersfield, GU31 4EX
Havant Borough Council, Public Service Plaza, Civic Centre Road, Havant PO9 2AX
Tel: 02392 446578
Email: robin.seamer@havant.gov.uk or robin.seamer@easthants.gov.uk

www.havant.gov.uk
www.facebook.com/havantboroughcouncil
www.twitter.com/havantborough

www.easthants.gov.uk
www.facebook.com/easthampshiredistrictcouncil
www.twitter.com/easthantsdc

Did you know that you can apply for Building Regulation approval at East Hampshire District Council and Havant Borough Council using the Planning Portal? <https://buildingcontrol.planningportal.co.uk/>

If you require a Building Control inspection and have a current Building Control application please phone 01730 234207 by 4pm the day before you want the inspection.