



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/23/00582

Our ref
DSA000027139

Date
28/09/2023

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Variation of conditions 4 and 5 of planning permission APP/22/00692 to relocate the building due south and 3 m away from existing onsite drainage.

Site: APP/23/00582: - Cowplain School, Hart Plain Avenue, Waterlooville, PO8 8RY.

Thank you for your letter dated 07/09/2023.

The submitted drawing (Drawing No: 01 Rev-A) indicating easement of 3.5 meter to the public surface water sewer would be satisfactory to Southern Water.

Southern Water has no objections to the above variation of condition 04 and 05.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development