

Clark, Jacky

From: Umunnakwe, Chima
Sent: 26 June 2023 10:44
To: Havant Planning and Development Mailbox New
Subject: APP/23/00155

Dear Planning Team,

Thank you for re-consulting the Pollution Team following my comments of 23rd March 2023.

My previous comments raised a couple issues bordering around noise and odour from the replacement ventilation system and the concerns regarding the impact on residential properties. The applicant has submitted a noise report prepared AirTight Acoustics. From the calculated noise data in accordance with BS4142 2014, the report concluded that it is unlikely to have an adverse impact on the nearest residential receptor receptors. The report addressed my previous concerns regarding anti-vibration mounts of the units. I am agreeing with the report's conclusions as it relates to noise. However, there are no details submitted regarding odour mitigation which was part of my previous objections. It is important that the applicant address this aspect and provide further detail on measures that will be implemented as part of this scheme to ensure that cooking odours are adequately mitigated in accordance with industry guidance.

I will be happy to review and provide a further response once this further information has been provided.

I hope this helps.

Regards

Chima Umunnakwe
Environmental Protection Officer (Planning Apps) | T: 07712673585
Environmental Health
Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

NB: My working hours is 18 hours and varies over the working week.