

Dear Planning,

I refer to the above consultation and I have no major concerns. However, should application be granted, I would like the following consideration to be made.

Artificial Light condition

Details of new external lighting of the site and access route shall be submitted to, and approved in writing by, the Local Planning Authority prior to the commencement of the development. This information shall include a layout plan with beam orientation and a schedule of equipment in the design (luminaire type, mounting height, aiming angles and luminaire profiles). The lighting shall be installed, maintained, and operated in accordance with the approved details unless the Local Planning Authority gives its written consent to the variation.

Reason: To protect the appearance of the area, the environment, and local residents from obstructive lighting.

Informative regarding Hours of Work:

You are hereby advised to ensure that no works or ancillary operations associated with any demolition, excavation, clearance, and construction works at the development, which are audible at the site boundary, shall take place on any Sunday or Bank / Public Holiday, nor on any other day except between the following times: Monday to Friday: 8.00 – 18.00 and Saturday: 8:00 – 13.00. This is to protect the occupants of nearby residential properties from noise and vibration nuisance.

Informative regarding Bonfires: You are hereby requested to ensure that no bonfires take place on this site, during any phase of the operation i.e., demolition, excavation, clearance, and construction works. If you feel you have a legitimate reason for a bonfire, it is recommended you enquire with the Environmental Health Pollution team, at Havant Borough Council, prior to taking this action. This is to protect the occupants of nearby residential properties from smoke pollution.

Informative regarding Dust Control:

You are hereby requested to ensure that the Environmental Health Pollution team, at Havant Borough Council are advised in writing as to what measures are to be put in place for the control of any dust that might emanate from the development site. This is to protect the occupants of nearby residential properties from dust pollution. Please do not hesitate to contact me if you wish to discuss any of the above matters raised or would like further explanation. Jonathan Driver of this office will likely provide separate comment on other issues.

I hope this helps.

Chima Umunakwe

Interim Pollution Team Leader / Planning Apps | T: 02392446397 : Mobile 07827070743

Environmental Health

Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

NB: Working days are Monday – Thursday (compressed)