

The designer has reduced the bath volume (but still within acceptable limits) and therefore including the external water use at 5 litres per person per day, the calculation is acceptable.

So this meets the requirement of the condition as it comes in under the 110 litres / person / day you are looking for.

Robin Seamer BSc (Hons) MRICS MCMI
Building Control Manager