

Further to the receipt of a revised water calculation forwarded to me on the 12th May 2023 in respect of the above, I can confirm that the water calculation has been assessed.

The assessment demonstrates that the calculation is satisfactory and therefore meets the requirements of Condition (14 a), namely “ A water efficiency calculation in accordance with the Government's National Calculation Methodology for assessing water efficiency in new dwellings has been undertaken which demonstrates that no more than 110 litres of water per person per day shall be consumed within the development”

**Robin Seamer BSc (Hons) MRICS MCMI
Building Control Manager**

East Hampshire District Council, Penns Place, Petersfield, GU31 4EX
Havant Borough Council, Public Service Plaza, Civic Centre Road, Havant PO9 2AX
Tel: 02392 446578

Email: robin.seamer@havant.gov.uk or robin.seamer@easthants.gov.uk

www.havant.gov.uk
www.facebook.com/havantboroughcouncil
www.twitter.com/havantborough

www.easthants.gov.uk
www.facebook.com/easthampshiredistrictcouncil
www.twitter.com/easthantsdc

Did you know that you can apply for Building Regulation approval at East Hampshire District Council and Havant Borough Council using the Planning Portal? <https://buildingcontrol.planningportal.co.uk/>

If you require a Building Control inspection and have a current Building Control application please phone 01730 234207 by 4pm the day before you want the inspection.