

Dear Planning Team,

Thank you for consulting the Pollution Team regarding the above application.

I understand the applicant seek discharge of updated Construction and Environmental Management Plan relating to condition 26-28 from PP/19/00007. I have reviewed the updated plan as prepared by RedRow (*RHSC/BRS/CEMP-D*). I have now reviewed the details as contained with the updated plan and I can advise that condition may be discharged.

Condition 30 – Piling Method Statement

The piling method statement does not provide sufficient ,mitigation measures with respect to noise and vibration which could impact on the adjacent crematorium and other residential receptors. The noise and vibration section should provide predicted noise levels and Vibration Dose Values at the nearest noise sensitive receptor including the crematorium. It is not considered that this aspect of the condition has been sufficiently addressed. There are other elements to condition 30 which requires impact to ground water and environmental sensitivity which my colleague may provide further comments in due course.

Based on the above details, we are unable to support that condition 30 be discharged.

Kind Regard

Chima Umunnakwe

Environmental Protection Officer (Planning Apps) | T: 07712673585

Environmental Health

Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

NB: My working hours is 18 hours and varies over the working week.