

LEGEND:



EX1
HOLOPHANE D-SERIES,
COLUMN/ BUILDING MOUNTED,
FORWARD THROW OPTIC,
22000 INITIAL LUMENS PER LAMP
COLOUR TEMPERATURE: 3000K
MAINTENANCE FACTOR = 1
WATTS PER LUMINAIRE = 208
MOUNTING HEIGHT = AS DETAILED
TILT ANGLE = 0
BLS INDICATES COLUMN LUMINAIRE IS
FITTED WITH A BACKWARDS LIGHT SHIELD

EX2
REMOVED FROM SCHEME

EX3
HOLOPHANE D-SERIES,
BUILDING MOUNTED,
FORWARD THROW OPTIC,
11000 INITIAL LUMENS PER LAMP
COLOUR TEMPERATURE: 3000K
MAINTENANCE FACTOR = 1
WATTS PER LUMINAIRE = 105
MOUNTING HEIGHT = AS DETAILED
TILT ANGLE = 0

EX4
HOLOPHANE D-SERIES,
COLUMN/ BUILDING MOUNTED,
FORWARD THROW OPTIC,
6500 INITIAL LUMENS PER LAMP
COLOUR TEMPERATURE: 3000K
MAINTENANCE FACTOR = 1
WATTS PER LUMINAIRE = 52
MOUNTING HEIGHT = AS DETAILED
TILT ANGLE = 0
BLS INDICATES COLUMN LUMINAIRE IS
FITTED WITH A BACKWARDS LIGHT SHIELD

EX5
HOLOPHANE D-SERIES,
COLUMN MOUNTED,
FORWARD THROW OPTIC,
5000 INITIAL LUMENS PER LAMP
COLOUR TEMPERATURE: 3000K
MAINTENANCE FACTOR = 1
WATTS PER LUMINAIRE = 34
MOUNTING HEIGHT = AS DETAILED
TILT ANGLE = 0
BLS INDICATES COLUMN LUMINAIRE IS
FITTED WITH A BACKWARDS LIGHT SHIELD



EX6
SCHREDER AXIA 3.2,
COLUMN MOUNTED,
OPTIC (5267),
9857 INITIAL LUMENS PER LAMP
COLOUR TEMPERATURE: 3000K
MAINTENANCE FACTOR = 1
WATTS PER LUMINAIRE = 69
MOUNTING HEIGHT = AS DETAILED
TILT ANGLE = 0
BLS INDICATES COLUMN LUMINAIRE IS
FITTED WITH A BACKWARDS LIGHT SHIELD

EX7
SCHREDER AXIA 3.2,
COLUMN MOUNTED,
OPTIC (5267),
10945 INITIAL LUMENS PER LAMP
COLOUR TEMPERATURE: 3000K
MAINTENANCE FACTOR = 1
WATTS PER LUMINAIRE = 78
MOUNTING HEIGHT = AS DETAILED
TILT ANGLE = 0
BLS INDICATES COLUMN LUMINAIRE IS
FITTED WITH A BACKWARDS LIGHT SHIELD



EX8
HOLOPHANE DENVER ID WALL,
BUILDING MOUNTED,
NARROW OPTIC,
1000 INITIAL LUMENS PER LAMP
COLOUR TEMPERATURE: 3000K
MAINTENANCE FACTOR = 1
WATTS PER LUMINAIRE = 12
MOUNTING HEIGHT = AS DETAILED



EX9
HOLOPHANE DENVER ELITE BOLLARD,
BOLLARD MOUNTED,
SYMMETRIC SINGLE LENS,
1000 INITIAL LUMENS PER LAMP
COLOUR TEMPERATURE: 3000K
MAINTENANCE FACTOR = 1
WATTS PER LUMINAIRE = 12
MOUNTING HEIGHT = AS DETAILED

1 LUX CONTOUR
0.5 LUX CONTOUR

THE RESULTS FOR EACH UNIT AND THE
ACCESS ROAD PRESENTED WITHIN THE
REPORT HAVE BEEN CALCULATED
SEPARATELY TO ELIMINATE RELIANCE ON
SPILL LIGHTING AND ENSURE REQUIRED
LEVELS ARE ACHIEVED, EVEN WHEN
NEIGHBOURING UNITS ARE UNOCCUPIED.
SPILL AND UWLR HAVE BEEN
CALCULATED WITH ALL LUMINAIRES ON
TO SHOW THE WORST CASE SCENARIO AS
SHOWN IN THIS DRAWING.

THIS DRAWING IS AN INDICATIVE LAYOUT ONLY, DEMONSTRATING
THE CONCEPTUAL REQUIREMENTS CORRELATING WITH THE
AGREED SCHEMATIC SOLUTIONS. THE PURPOSE OF THIS DRAWING
IS TO DEMONSTRATE DESIGN INTENT, FOR FURTHER
DEVELOPMENT BY THE RELEVANT SERVICES DESIGNER ONLY.

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE
ELECTRICAL PERFORMANCE SPECIFICATION & ALL RELEVANT
ARCHITECTURAL ENGINEERING DRAWINGS. DETAILED & FULLY
COORDINATED INSTALLATION DRAWINGS SHALL BE PROVIDED BY
THE ELECTRICAL CONTRACTOR IN ACCORDANCE WITH THE
SPECIFICATION.

1	REVISIONS	REVISED AND LAYOUT FOR COMMENTS	CP	ST
2	REVISIONS	REVISED FOR PLANNING	CP	ST
3	REVISIONS	REVISED FOR PLANNING	CP	ST
4	REVISIONS	REVISED FOR PLANNING	CP	ST
5	REVISIONS	REVISED FOR PLANNING	CP	ST
6	REVISIONS	REVISED FOR PLANNING	CP	ST
7	REVISIONS	REVISED FOR PLANNING	CP	ST
8	REVISIONS	REVISED FOR PLANNING	CP	ST
9	REVISIONS	REVISED FOR PLANNING	CP	ST
10	REVISIONS	REVISED FOR PLANNING	CP	ST
11	REVISIONS	REVISED FOR PLANNING	CP	ST
12	REVISIONS	REVISED FOR PLANNING	CP	ST
13	REVISIONS	REVISED FOR PLANNING	CP	ST
14	REVISIONS	REVISED FOR PLANNING	CP	ST
15	REVISIONS	REVISED FOR PLANNING	CP	ST
16	REVISIONS	REVISED FOR PLANNING	CP	ST
17	REVISIONS	REVISED FOR PLANNING	CP	ST
18	REVISIONS	REVISED FOR PLANNING	CP	ST
19	REVISIONS	REVISED FOR PLANNING	CP	ST
20	REVISIONS	REVISED FOR PLANNING	CP	ST

Interface 100
Aston Way, Solihull
B90 4JH

Phone
+44(0) 121 709 6600
birmingham@cpw.com

RIBA Stage

STATUS

Client

Project

DUNSBURY PARK
PORTSMOUTH

Drawing Title

UNIT 501 & 502
ELECTRICAL SERVICES INSTALLATION
PROPOSED EXTERNAL LIGHTING LAYOUT

Scale (MM)

1:500

Date

SEP 21

By

KM

VS

CPW Project No. 2208

DP-CPW-ZZ-XC-DR-E-2201-1

Linked Files

STAGE 3

PLANNING



Project

DUNSBURY PARK
PORTSMOUTH

Drawing Title

UNIT 501 & 502
ELECTRICAL SERVICES INSTALLATION
PROPOSED EXTERNAL LIGHTING LAYOUT

Scale (MM)

1:500

Date

SEP 21

By

KM

VS

CPW Project No. 2208

DP-CPW-ZZ-XC-DR-E-2201-1

Linked Files

NOTES:

- ELECTRICAL CONTRACTOR TO VERIFY LIGHTING DESIGN PRIOR TO INSTALLATION AS THIS IS ONLY A CONCEPTUAL DESIGN.
- ELECTRICAL CONTRACTOR TO READ THIS DRAWING IN CONJUNCTION WITH THE PROJECT SPECIFICATIONS.
- ELECTRICAL CONTRACTOR TO ENSURE CABLES AND LIGHTING COLUMNS ARE LOCATED SUCH THAT THEY WILL NOT BE AFFECTED BY THE FUTURE GROWTH OF THE TREE ROOT, ETC.
- ALL EXTERNAL LIGHTING IS TO BE CONTROLLED WITH A PHOTO CELL (LOCATION TO BE CONFIRMED) SUCH THAT THE LIGHTING WILL ENERGISE AT LOW AMBIENT LIGHTING AND WILL REMAIN OPERATIONAL DURING THE HOURS OF DARKNESS.
- THE LIGHTING DESIGN TO COMPLY WITH THE CIBSE GUIDE LOGS THE OUTDOOR ENVIRONMENT. BS EN 12464-2 LIGHTING OF WORK PLACES. BS 5489-1:2013 CODE OF PRACTICE FOR DESIGN OF ROAD LIGHTING AND ALL LATEST ADDITIONS.
- NO SHRUBBERY/FOLIAGE HAS BEEN ALLOWED WITHIN THE LIGHTING CALCULATION TO ALLOW FOR WORST CASE ON THE LIGHTING OVERSILL.
- ACCESS ROAD LIGHTING SHALL BE INSTALLED IN ACCORDANCE WITH HAMPSHIRE COUNTY COUNCIL TECHNICAL GUIDANCE NOTE TG13 - STREET LIGHTING.
- SPILL LIGHTING HAS ALSO BEEN CALCULATED WITH ALL LUMINAIRES ON TO SHOW THE WORST CASE RESULTS.
- ALL LUMINAIRE TO HAVE A COLOUR TEMPERATURE OF 3000K (IN LINE WITH THE ECOLOGIST REQUIREMENTS).
- ROAD LIGHTING DESIGNED TO COMPLY WITH BS5489-1:2013 CODE OF PRACTICE FOR DESIGN OF ROAD LIGHTING.
- ALL LIGHTING COLUMNS AND LANTERNS TO BE IN THE SAME COLOUR AND FINISH, TO BE AGREED WITH CLIENT PRIOR TO TENDER. ALL ACCESS ROAD FITTINGS AND COLUMNS SHALL BE TO HAMPSHIRE COUNTY COUNCIL ADOPTABLE STANDARDS. ALL BUILDING MOUNTED LUMINAIRES TO MATCH CLADDING COLOUR AS CLOSE AS POSSIBLE USING STANDARD RAL COLOURS.
- ALL DRAWINGS TO BE READ IN CONJUNCTION WITH THE CPW EXTERNAL LIGHTING REPORT.
- ACCESS ROAD PEDESTRIAN CROSSING COLUMNS (REF EX7) TO BE INSTALLED WITH BELISHA BEACONS IN ACCORDANCE WITH HAMPSHIRE COUNTY COUNCIL REQUIREMENTS.
- CALCULATIONS INCLUDE A 2.4M SOLID FENCE ON THE EASTERN BOUNDARY OF THE SERVICE YARD ON UNITS 501 & 502.