

Hello Arleta,

Thank you for sending across the revised site plan.

Unfortunately the amendments have not addressed my initial comments so they would still stand:

- We have concerns with the proposed weld mesh fencing, from a safe guarding perspective a solid boundary treatment would be more appropriate given the ages of the children using the play area. Given the visually prominence within the open space a brick wall would be more appropriate and will increase security of the site.
- Concerns with who will be maintaining the trees alongside Spencer Road given the area of open space if owned by HBC.

Kind regards,

Harry Mitchell CMLI

Chartered Landscape Architect | M: 07883072179

Civil Engineering and Landscape Team, Havant Borough Council, Public Service Plaza, Havant, PO9 2AX



Your privacy matters. Go to www.havant.gov.uk/privacy-policy

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.