

Dear Planning Team,

Thank you for consulting the Pollution Team on the above application.

This email relates to condition 13 (Construction Environmental Management Plan) from the decision notice APP/21/00189 . The applicant has submitted a construction method statement by Readie dated 22nd October 2022 in support of the application. Section 3 stated some proposal for noise monitoring, however this considered very limited and does not provide a detailed measures to control the effects of noise and vibration during construction activities. The report could have been more robust in terms of measurement and monitoring of noise and vibration. I am not satisfied that the submitted document has addressed the condition fully.

I have a look at the Sharps redmore report and I am of the view that it assesses the impact of construction activities, however, the CEMP should provide greater detail on how the noise and vibration is to be managed based on the assessment.

For the above reasons, discharge is not supported. The applicant should consider all aspect of the submitted report and provide sufficient information relating to noise/Vibration and other environmental nuisance to demonstrate that these matter have been fully considered.

Kind Regards

Chima Umunnakwe

Environmental Protection Officer (Planning Apps) | T: 07712673585

Environmental Health

Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

NB: My working hours is 18 hours and varies over the working week.