

# Consultee Comments for Planning Application APP/20/00935

## Application Summary

Application Number: APP/20/00935

Address: 11 East Street, Havant, PO9 1AB

Proposal: Erection of 6No. 3bed dwellings, with 4 No. car parking spaces.

Case Officer: David Eaves

## Consultee Details

Name: Mrs Sally Nixon Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

## Comments

Comments

This property is in a Radon area so consideration under AD C will be required

Works maybe within 3m of a public sewer. Consult with SWS

Compliance with AD B5 Fire Authority access to be shown

Bin storage provisions should comply with AD H

Building Consent will be needed for this application