

APP/22/01136

Dear Planning Team,

Thank you for consulting us on the above application. I can confirm that we have no adverse comments to make concerning the proposal. However, I can advise that should planning permission be granted we require details of sound insulation performance standards of the proposed residential units. Accordingly, we advise that the following condition and informative be imposed.

Sound transmission reduction condition

Prior to commencement of the development the applicant shall provide a scheme to the Local Planning Authority for its written approval detailing sound transmission reduction measures to be installed within the separating walls between the proposed dwellings and existing commercial premises that share a party wall to limit airborne sound transmission.

The scheme shall be designed to be 5dB better than that given in Approved Document E (2003 Edition incorporating 2004 and 2010 amendments) of the Building Regulations (Table 0.1a, page 12). Once agreed in writing by the Local Planning Authority the approved details shall be installed prior to the development being occupied and retained thereafter.

Construction/ Demolition Management

No development shall commence, including demolition and site clearance works, until a Construction Management Plan (CMP), to include details of: (a) provision of boundary hoarding; (b) hours of operation; (c) means to control dust and emissions to air; (d) means to control noise and vibration has been submitted to, and approved in writing by, the Local Planning Authority. The CMP should be in accordance with the GLA's Supplementary Planning Guidance 'Control of Dust and Emissions during Demolition and Construction'. The development shall be constructed in accordance with the approved statement. Reason: To ensure that the proposed development does not have a significant adverse impact on the amenities of nearby residential properties and to minimise the impacts on local air quality.

Reason: To safeguard the amenity of the neighbours by minimising impacts of the development that would otherwise give rise to nuisance.

Informative regarding Hours of Work:

You are hereby advised to ensure that no works or ancillary operations associated with any demolition, excavation, clearance and construction works at the development, which are audible at the site boundary, shall take place on any Sunday or Bank / Public Holiday, nor on any other day except between the following times: Monday to Friday: 8.00 – 18.00 and Saturday: 8:00 – 13.00. This is in order to protect the occupants of nearby residential properties from noise and vibration nuisance

Informative regarding Bonfires: You are hereby requested to ensure that no bonfires take place on this site, during any phase of the operation i.e. demolition, excavation, clearance and construction works. If you feel you have a legitimate reason for a bonfire, it is recommended you enquire with the Environmental Health Pollution team, at Havant Borough Council, prior to taking this action. This is in order to protect the occupants of nearby residential properties from smoke pollution.

Informative regarding Dust Control:

You are hereby requested to ensure that the Environmental Health Pollution team, at Havant Borough Council are advised in writing as to what measures are to be put in place for the control of any dust that might emanate from the development site. This is in order to protect the occupants of nearby residential properties from dust pollution. Please do not hesitate to contact me if you wish to discuss any of the above matters raised or would like further explanation. Jonathan Driver of this office will in all likelihood provide separate comment on other issues.

Kind Regards

Chima Umunnakwe

Environmental Protection Officer (Planning Apps) | T: 07712673585

Environmental Health

Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

NB: My working hours is 18 hours and varies over the working week.