

From: Gargett, Jamie
Sent: 25 January 2021 16:55
To: Haywood, Daphney <Daphney.Haywood@havant.gov.uk>
Subject: Re: Planning Application APP/20/01093 Land at Sinah Lane, Hayling Island

Daph

From the ACD plan provided , tree Protection appears to be adequate for the site and should ensure the trees identified for retention are afforded measures to ensure they are not damaged during the construction phase. If permission is given the a full AIA to include the AMS and this TPP must be conditioned ensure that the tree protection is in place prior to any works (to include exploratory tasks such as archaeological survey digs etc) and signed off by their Arb consultant with submitted photographic records.

Thanks
J

Jamie Gargett MICFor
Arboriculture Manager
East Hampshire District Council, Penns Place Petersfield, GU31 4EX
Havant Borough Council, Public Service Plaza, Civic Centre Road, Havant, PO9 2AX

Telephone 02392 446525 Email Jamie.gargett@havant.gov.uk

www.easthants.gov.uk

www.facebook.com/easthampshiredistrictcouncil

www.twitter.com/easthantsdc

www.havant.gov.uk

www.facebook.com/havantboroughcouncil

www.twitter.com/havantborough