

From: McMurray, Rachael <Rachael.McMurray@havant.gov.uk>
Sent: 21 April 2021 10:52
To: Wells, Lesley <Lesley.Wells@easthants.gov.uk>
Subject: RE: Condition 7 of APP/19/00156 and Condition 6 of APP/19/00157

Hi Lesley,

Based on Derek's response and description of how the works will be carried out, I am content to discharge the relevant conditions on APP/19/00156 and APP/19/00157.

Kind regards

Rachael

Rachael McMurray

Senior Conservation Planner MRTPI | T: 02392 446546

Shared Heritage Team

RegenCo Heritage (part of RegenCo)
Havant Borough Council, Public Service Plaza, Havant, PO9 2AX
East Hampshire District Council, Penns Place, Petersfield, GU31 4EX

ADVANCE NOTICE OF LEAVE – 25 MARCH (INCLUSIVE) RETURNING ON 12 APRIL 2021

Your privacy matters. Go to www.havant.gov.uk/privacy-policy

Your privacy matters. Go to easthants.gov.uk/privacy-policy

Information in this message is confidential and may be privileged. It is intended solely for the person to whom it is addressed. If you are not the intended recipient, please notify the sender, and please delete the message from your system immediately.

From: Wells, Lesley
Sent: 20 April 2021 15:51
To: McMurray, Rachael <Rachael.McMurray@havant.gov.uk>
Subject: FW: Condition 7 of APP/19/00156 and Condition 6 of APP/19/00157

Hi Rachael

With regard to Derek's response below, can we now sign off the above 2 conditions please?

Many thanks Lesley

From: Derek@solentplans.co.uk <Derek@solentplans.co.uk>
Sent: 30 March 2021 15:33

To: Wells, Lesley <Lesley.Wells@easthants.gov.uk>

Subject: RE: Condition 7 of APP/19/00156 and Condition 6 of APP/19/00157

Hi Lesley/ Rachael

I am happy to confirm we will not add false ceilings and will carry out the new works from above as requested by Rachael. The space between window heads and ceiling makes an additional lower ceiling unachievable.

Instead we will cut out floor sections within the first floor rooms (We will not lift to the edges to preserve the existing first floor skirtings and architraves) We will then lay a monarfloor acoustic floor treatment over the top and fire line board and acoustic roll between the existing joists. Building control have offered a relaxation for sound but insist on the Fire treatment.

Derek



WWW.Solentplans.com - info@solentplans.com - Tel: 02392 580745 - mob: 07771355742