

From: Kris Mitra
Sent: 18 March 2021 12:08
To: Wells, Lesley
Subject: RE: Coldharbour Farm Road
Importance: High

Dear Lesley

Further to your request please find attached the section plan you requested. On each of the floor plans the levels are indicated. We note the requirement from the EA to comply with a FFL of 6.9m AOD and I believe the FFL's are compliant.

To update you we are still in discussions with the EA over the access road and flooding and will come back to you once an acceptable position has been agreed with them.

Kind regards

Kris
Kris Mitra MA MRTPI
Managing Director
Kris@genesistp.co.uk

26 Chapel Street
Chichester
West Sussex
PO19 1DL

Tel: 01243 534050
Mob: 07770 777991



www.genesistp.co.uk



Sponsors of the Surrey Property Awards 2019

