



Hampshire County Council

*Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD*

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

<i>Enquiries to</i>	Santiago Manzanero	<i>My reference</i>	SWM/2020/0589
<i>Direct Line</i>	01962 846777	<i>Your reference</i>	APP/20/00933
<i>Date</i>	5 February 2021	<i>Email</i>	SWM.consultee@hants.gov.uk

Dear Sir/Madam,

Demolition of existing retail unit (no. 9 East Street) and construction of 10 no. supported living units, use Class C2 at 9 East Street, Havant, PO9 1AA.

Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application in our role as statutory consultee on surface water drainage for major developments.

In order to assist applicants in providing the correct information to their Local Planning Authority for planning permission, Hampshire County Council has set out the information it requires to provide a substantive response at <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning>

The County Council has reviewed the following documents relating to the above application:

- Drainage General Arrangement; Drg No. 414601.10P2; dated: Oct 2020.
- CAUSEWAY detailed hydraulic calculations: Network: Storm Network 1; dated: 22/01/2021.
- Drainage Details; Drg No: 414601.11P2; dated: Oct 2020.
- Existing and Proposed Runoff Rates Calculations.

Following our formal response to this planning application dated 06th November 2020, we received additional information on the 17th November 2020 and on the 25th January 2020 including the requested detailed hydraulic calculations and drainage drawings.

Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI

The additional information has addressed our concerns regarding surface water management and local flood risk. Therefore, the County Council as the Lead Local Flood Authority has **no objection** to the proposals subject to the following planning conditions:

1. The drainage system shall be constructed in accordance with the Drainage General Arrangement ref: 414601.10P2. Surface water discharge to the public sewer network shall be limited to 6.42 l/s. Any changes to the approved documentation must be submitted to and approved in writing by Local Planning Authority and Lead Local Flood Authority. Any revised details submitted for approval must include a technical summary highlighting any changes, updated detailed drainage drawings and detailed drainage calculations.
2. The condition of the existing drainage system should be investigated before any connection is made. If necessary, improvement to its condition as reparation, remediation, restitution, and replacement should be undertaken. Evidence of this, including photographs should be submitted. Evidence that Asset Owner has agreed to the principle connection and discharge rate should be submitted before any connection is made.
3. Details for the long-term maintenance arrangements for the surface water drainage system shall be submitted to and approved in writing by the Local Planning Authority prior to the first occupation of any of the dwellings. The submitted details shall include:
 - a. Maintenance schedules for each drainage feature type and ownership.
 - b. Details of protection measures.

We would also recommend that the applicant is directed to our website <http://www3.hants.gov.uk/flooding/hampshireflooding/drainagesystems.htm> for further information on recommended surface water drainage techniques.

Please note that Hampshire County Council as Lead Local Flood Authority will not comment on the fluvial systems as these are outside our remit.

As a statutory consultee, the County Council has a duty to respond to consultations within **21 days**. The 21-day period will not begin until we have received sufficient information to enable us to provide a meaningful response. Please ensure all data is sent to us via the relevant Local Planning Authority.

For guidance on providing the correct information, please review the checklist and associated guidance document available on our [website](#).

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,



Flood and Water Management Team
Economy, Transport & Environment Department,
Hampshire County Council, 1st Floor, Ell Court West,
The Castle, Winchester, Hampshire SO23 8UD
Web: <http://www3.hants.gov.uk/flooding/watercourses.htm>

General guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

Works in relation to ordinary watercourses

PLEASE NOTE: *If the proposals include works to an ordinary watercourse, under the Land Drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.***

Information on ordinary watercourse consenting can be found at the following link <http://www3.hants.gov.uk/flooding/hampshireflooding/watercourses.htm>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

*For guidance on providing the correct information, we recommend you use our **Ordinary Watercourse Consents Pre-application service** and help avoid delays occurring at the formal application stage. A Pre-application service for Ordinary Watercourse Consents is available, allowing consents to go through in a smoother, often more timely manner. For full information please visit:*

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/WatercoursePreApplication>