

I have reviewed the application and have concerns about the potential for noise from the proposed compressor to adversely impact residential amenity, especially the flats above.

Whilst the applicant has provided a 'Fushionscroll brochure' it is not clear which compressor they propose to install, what the noise levels will be at the nearest noise sensitive premises or what hours the plant will be used, e.g. daytime or 24/7. From the ground floorplan it appears that two compressors may be proposed and they will be contained in some kind of enclosure, but no information has been provided on whether the enclosure will provide any sound attenuation from the unit(s).

As the application contains insufficient information on noise I am unable to provide full comments on the proposal. I recommend the applicant provides further information to demonstrate that any adverse noise impacts from the proposed compressor(s) will be appropriately mitigated.

Please do not hesitate to contact me if you require any further information.

Regards

Gemma Richards

Pollution Team Leader | T: 01730 234322

Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

East Hampshire District Council, Penns Place, Petersfield, GU31 4EX

My working pattern – Wednesday, Thursday and Friday