

Please see attached the amended layout. The access serving Plots 3-5 has been widened to 4.8m and the full sprinkler system included as requested.

The ground floor window of Plot 2 will be a fixed fire rated window and as such, will comply with Building Regs.

Kind regards

Kimberley

Kimberley Parry PhD MRTPI