

Report on Site Levels

Point on Plan*	Build Status	Structure measured	Approved Level	As-Built Level
Plot 1	Structural Slab Level	Structural Slab Level	8.275 (FFL 8.500)	8.260
Plot 2	Structural Slab Level	Structural Slab Level	8.275 (FFL 8.500)	8.260
Plot 3	Structural Slab Level	Structural Slab Level	6.975 (FFL 7.200)	6.965
Plot 4	Structural Slab Level	Structural Slab Level	6.975 (FFL 7.200)	6.965
Plot 5	Structural Slab Level	Structural Slab Level	6.075 (FLL 6.300)	6.080
Plot 6	Structural Slab Level	Structural Slab Level	6.075 (FFL (6.300)	6.080
Plot 7	N/A	N/A	6.025 (FFL 6.250)	N/A
Plot 8	N/A	N/A	5.575 (FFL 5.800)	N/A
Plot 9	N/A	N/A	5.575 (FFL 5.800)	N/A
Plot 10	N/A	N/A	5.275 (FFL 5.500)	N/A
Road – point 1	Base course (tarmac to 40mm still required)	Primary Road Contour	8.65	8.60
Road – point 2	As above	Primary Road Contour	7.50	7.450
Road – point 3	As above	Primary Road Contour	7.10	7.030
Road – point 4	As above	Primary Road Contour	6.80	6.75
Road – point 5	As above	Primary Road Contour	6.20	6.150
Road – point 6	N/A	N/A	N/A	N/A

*marked up plan overleaf. See also: approved plan BSO/E4519/008 G

Levels Measured by: Graceland's Setting Out Engineer

Signed: Senior Technical Manager

Malcolm Westcott

Date Measured: 02/03/21

