

B. WILLIAMSON & DAUGHTERS

COPSE COTTAGE, FORD MANOR ROAD, DORMANSLAND, SURREY, RH7 6NZ

OFFICE 01342 834829 MOBILE 07710 854497

Email: b.williamson57@hotmail.com

Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

16th December 2020

Dear Ms K Mabbs

Ref APP/20/01119

RE: 9 Langstone, High Street, Langstone, Havant, Hampshire, PO9 1RY

Following your letter dated 4th December

We would not be changing any part of the building

The chimney stack has suffered from frost attack owing to water ingress from above causing the bricks to decay, as shown in the attached picture


We would normally have removed the damaged bricks and replaced them, but having assessed the damage we think it is too far gone and could collapse

Our proposal is to take it down to the damaged level, set aside all the bricks and rebuild in sand and lime, re-flaunch and re-flash around the chimney to stop any further ingress of water

Please do not hesitate to contact us should you require any further information.

Yours Faithfully

Bryan Williamson





9 LANGSTONE, HAVENT
REF APP/20/01119.