

Registered Office:
Portsmouth Water Ltd
PO Box 8
Havant
Hampshire PO9 1LG

Tel: 023 9249 9888
Fax: 023 9245 3632
Web: www.portsmouthwater.co.uk

**CONSULTATION UNDER THE TOWN AND COUNTRY PLANNING
(DEVELOPMENT MANAGEMENT PROCEDURE ENGLAND) ORDER 2015**

Planning Application Reference:	APP/20/00735
Proposal:	Internal alterations resulting in increase in flats and studios from 26 units (41 persons) to 29 units (40 persons) including 1 x disabled person unit. Replacement of windows and doors on whole building, blue panels below some windows, removal of dwarf wall to front (west) elevation and replacement with 1.2m high round top fence and gate. Main entrance changed from west to east elevation. Alterations to doors and windows on east elevation. 3 x rain canopies to east elevation. Replacement bin store. Alterations to car park. Alterations to landscaping. Installation of 2 x smoking canopies and 1 covered cycle store. New timber fencing. Installation of 4 x CCTV camera points.
Location:	Brent House, 12 Middle Park Way, Havant
Date:	13 November 2020

Portsmouth Water have reviewed the application for internal alterations at Brent House.

The site is located in Source Protection Zone 1c (SPZ1c) for an essential public water supply source. The SPZ1c relates to subsurface activity only, where the Chalk aquifer is confined and may be impacted by deep drilling activities. Subterranean activities may pose a risk to groundwater quality and the local public water supply source.

Portsmouth Water have no adverse comments on this application as there is no piling and/or deep excavations which will impact the underlying Principal Aquifer as part of these works.

Catchment Management Team
Portsmouth Water

catchment.management@portsmouthwater.co.uk