

**Registered Office:**  
Portsmouth Water Ltd  
PO Box 8  
Havant  
Hampshire PO9 1LG

Tel: 023 9249 9888  
Fax: 023 9245 3632  
Web: [www.portsmouthwater.co.uk](http://www.portsmouthwater.co.uk)

**CONSULTATION UNDER THE TOWN AND COUNTRY PLANNING  
(DEVELOPMENT MANAGEMENT PROCEDURE ENGLAND) ORDER 2015**

|                                        |                                                                                        |
|----------------------------------------|----------------------------------------------------------------------------------------|
| <b>Applicant:</b>                      | <b>Bargate Homes and Vivid</b>                                                         |
| <b>Planning Application Reference:</b> | <b>APP/20/00966</b>                                                                    |
| <b>Proposal:</b>                       | <b>Demolition of 1983 office building and associated brick and glass corridor link</b> |
| <b>Location:</b>                       | <b>Southleigh Park House, Eastleigh Road, Havant, PO9 2PE</b>                          |
| <b>Date:</b>                           | <b>06 November 2020</b>                                                                |

Portsmouth Water have reviewed the application for the **Demolition of 1983 office building and associated brick and glass corridor link** and have the following observations to make.

The site lies on made ground overlying superficial deposits, which in turn overlie Bedrock. The Superficial Deposits are Head (Clay, Silt, Sand and Gravel) deposits and the Bedrock consists of London Clay Formation. The geology underlying the site is classified as an Unproductive Aquifer overlying a Principal Aquifer.

The site is located in Source Protection Zone 1c (SPZ1c) for an essential public water supply source. The SPZ1c relates to subsurface activity only, where the Chalk aquifer is confined and may be impacted by deep drilling activities. Subterranean activities may pose a risk to groundwater quality and the local public water supply source.

Portsmouth Water have no adverse comments on this application as there is no deep drilling and/or deep excavations which will impact the underlying Principal Aquifer as part of these demolition works.

Catchment Management Team  
*Portsmouth Water*

[catchment.management@portsmouthwater.co.uk](mailto:catchment.management@portsmouthwater.co.uk)