

Arboricultural Officer comments:

I note the preliminary foundation scheme plan which has been submitted. This scheme is achievable providing there is a detailed site specific step by step method statement submitted. At present I am still concerned that it needs to be made clear that no work should commence until the cellular confinement surfacing is in place or at the very least ground protection. A condition will still need to be added for a finalised method statement and foundation design to be submitted please.

Thanks

Maria Stewart - Arboricultural Officer