

For the Attention of Mr L Oliver

Planning & Development
Havant Borough Council
Public Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Hampshire Fire and Rescue Service HQ
Business Fire Safety
Leigh Road
Eastleigh
Hampshire
SO50 9SJ

Tel: 023 8062 6751

Email: csprotection.admin@hantsfire.gov.uk

Date: 17 November 2020

Enquiries To: Mr Bart (Charles) Forster

My Reference: F6/CBF/00834740

Mobile Tel:

Your Reference: APP/20/00990

Dear Mr Oliver

Town & Country Planning Act 1990

Fire and Rescue Services Act 2004

Planning Application Number: APP/20/00990

Havant Thicket, adjacent to Sir George Staunton Country Park, Middle Park Way, Havant

Drawings and Documents Referenced

Title	Project Ref / No	Drawing No / Documents	Revision	Date
Havant Portal	APP/20/00990	All relevant	No info	11-11-2020
Fire Consultation Letter	APP/20/00990	No info	No info	16-11-2020

Description of Works:

HFRS understands that the project involves development of a reservoir for raw water storage. A pumped storage reservoir, with the minimum required total storage capacity of 8,700 million litres (ML), to support the planned bulk supply transfer of at least 21ML/d in extreme (currently defined as 1:200 year) drought conditions; Construction of an earth embankment adjacent to Staunton Country Park Construction of an overflow discharge/spillway at the south-western side of the reservoir and associated works; Construction of a new junction on the B2149 Manor Lodge Road and a new junction on Swanmore Road. Provision of viewing areas on the southern embankment and western edge of the reservoir. 2) Outline application for (matters to be considered outlined in Table 2.2 in the submitted Development Specification) control house partially incorporated within landscaped earth mounding adjacent to the south west embankment; together with provision of other earth embankments.

Construction of a visitor centre / cafe, with storage areas and welfare facilities to the northwest of the reservoir to be used for recreational and education purposes; Provision of picnic area(s) and children's play area(s). Access routes from both junctions to the visitor car park; visitor car park comprising 193 car parking spaces and between 70 and 75 overflow spaces plus spaces for staff, coach/minibus and disabled drivers sited to the north west of the reservoir.

Creation of a permanent wetland on the northern side of the reservoir and construction of bird watching hide/screen(s); recreational facilities for public amenity. Provision of perimeter tracks and a network of bridleways, cycle paths and footpaths; Construction of a slipway on the western bank of the reservoir for operational use only and a small section of the proposed pipeline (210m).

I confirm that Hampshire Fire and Rescue Service (HFRS) has received your application, dated 16 November 2020. The inspector named above has considered the information provided and has made the following comments:

Building Regulations: Access for Firefighting

Access and facilities for Fire Service Appliances and Firefighters should be in accordance with Approved Document B5 of the current Building Regulations.

Hampshire Act 1983 Section 12 – Access for Fire Service

Access **to** the proposed site should be in accordance with Hampshire Act 1983 Sect, 12 (Access to buildings **within the site** will be dealt with as part of the building regulations application at a later stage). Access roads **to** the site should be in accordance with Approved Document B5 of the current Building Regulations.

Fire and Rescue Services Act 2004

The following recommendations are advisory only and do not form part of any current legal requirement of this Authority.

Access for High-reach Appliances

High reach appliances currently operated by the HFRS exceed the maximum requirements given in Section 17 of the Approved Document B. When considering high rise buildings these variations should be considered as additions and incorporated as follows. Structures such as bridges, which a high-reach appliance may need to cross should have a maximum carrying capacity of 26 tonnes. Where the operation of a high reach vehicle is envisaged, a road or hard standing is required 6m wide. In addition, the road or hard standing needs to be positioned so that its nearer edge is not less than 3m from the face of the building.

Water Supplies

Additional water supplies for firefighting may be necessary. You should contact the Community Response Support, Hampshire Fire and Rescue Headquarters, Leigh Road, Eastleigh, SO50 9SJ (risk.information@hantsfire.gov.uk) to discuss your proposals.

Fire Protection

HFRS would strongly recommend that consideration is given to installation of an Automatic Water Fire Suppression Systems (AWFSS) to promote life safety and property protection within the premises.

HFRS is fully committed to promoting Fire Protection Systems for both business and domestic premises. Support is offered to assist all in achieving a reduction of loss of life and the impact of fire on the wider community.

Testing of Fire Safety Systems

HFRS strongly recommends that, upon commissioning, all fire safety systems are fully justified, fully tested and shown to be working as designed. Thereafter, their effectiveness should be reconfirmed periodically throughout their working lifecycles.

Firefighting and the Environment

Should a serious unsuppressed fire occur on the premises, the water environment may become polluted with 'fire water run-off' that may include foam. The Service will liaise with the Environment Agency at any incident where they are in attendance and under certain circumstances, where there is a serious risk to the environment, a 'controlled burn' may take place. This of course could lead to the total loss of the building and its contents.

Premises' occupiers have a duty to prevent and mitigate damage to the water environment from 'fire water run off' and other spillages.

If have any queries concerning these matters may be directed to the inspector named above, but all correspondence should be addressed to the Chief Officer.

Please quote our reference number on all correspondence.

Yours sincerely



Neil Odin
Chief Officer