

From: CAAD Ltd
Sent: 26 October 2020 09:33
To: Wells, Lesley
Subject: APP/20/00725 - Pontoon Extension, Wilsons Boatyard. H.I.

Good Morning Lesley/Amelia

With regards to the above, there are a number of outstanding queries which I will reply to, in the next day or two.

In particular respect to the **construction method**: There will be no on site work of any significance. There is a large pile at the end of the existing pontoon. This will serve the new extension, which will continue beyond the pile. There will not be any new piling. The pontoon extension will be floated in to site, and bolted on to the end of the existing pontoon. The makers of the new pontoon are those who installed the existing pontoon, and as such, the connection fittings will be fully compatible.

I hope this clarifies the proposal.

Thank you.

Martin

Martin Critchley.

(19058)

The CAAD Team
Architecture & Design Services



Critchley Architecture And Design (CAAD) Ltd.

02392 474919 / 07411 395150

info@caad.online

The Old Brewery, 15E South Street, Havant, PO9 1BU