

Client sign Off Design Drawings

Drawing Ref – FL3320 – 1

Job ref – M2127

PO – SCORR023094

Client – Engie


Contact – Jake Surtees East -

Site – Fox Lea House, Rest Awyle, Rd, PO11 0PG.


Door Spec

- RAL – 7035 MAT finish
- Glazing – clear 10.8 Laminate
- Aluminum Anti Finger Trap Door and Frame SBD certified
- Locking on 3no Mag Locks rebated into door and frame
- Lock Release – Push to exit on frame or wall where applicable
- Concealed transom Closer
- Handle – 300mm Stainless D Handle & Anodised push plate
- Low DDA compliant threshold
- Intercoms – **Engie to Confirm Status**
- Electrical connection – **Has not been instructed at present**

33 – 55a Foxleas Front



33 – 55a Foxleas Rear



Please Note current doors are a set of double doors the proposed design to enhance security is single door with side screen leaving a 1m clear opening to the door.

Rear Door has NO power please advise on locking and power.