

From: Fitzgerald, David

Sent: 10 November 2020 12:38

To: Eaves, David

Subject: Urgent APP/20/00833 | Erection of a flexible power generation facility with associated ancillary infrastructure, access and boundary treatment | Power Generation Facility, Southmoor Lane, Havant, PO9 1JW

Importance: High

Dear David

I would recommend refusal at this point as the reports that have been submitted ,:

- Acoustic Report (from Nova Acoustics) and
- Air quality report by Redmore International,

Have not considered the impact on the nearest residential units (49, 51 brookside road, Havant) .

I'm happy that once the reports have been corrected to take account of these dwellings the applications is reviewed by environmental Health and informed comments can be made.



David Fitzgerald

Environmental Protection Manager (Pollution & Animal

East Hampshire District Council

Penns Place, Petersfield GU31 4EX

Telephone: 01730 234323

Email: David.fitzgerald@easthants.gov.uk

www.easthants.gov.uk

<https://www.facebook.com/EastHampshireDistrictCouncil>

www.twitter.com/easthantsdc

Your privacy matters, go to www.easthants.gov.uk/privacy-policy

Havant Borough Council

Public Service Plaza, Civic Centre Road,

Havant PO9 2AX

Telephone: 01730 234323

Email: David.fitzgerald@easthants.gov.uk

www.havant.gov.uk

www.facebook.com/havantborough

www.twitter.com/havantborough

Your privacy matters, go to

www.havant.gov.uk/privacy-policy