



WATER
for **LIFE**

from
Southern
Water 

Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/17/01243

Our ref
PLAN-035016

Date
05/10/2020

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Condition 18.

Site: APP/17/01243: - 208 London Road, Waterlooville, PO7 7AN.

Thank you for your letter dated 15/09/2020.

Southern Water shall have no objections to discharge condition 18 relating to foul drainage. An approval for the connection to the public sewer should be submitted under Section 106 of the Water Industry Act.

Southern Water cannot recommend discharge of condition 18 related to surface water drainage. The surface water drainage for the site should be designed based on the preferred order of hierarchy for surface water disposal as defined in Part H3 of the Building Regulations. They should be consulted on possible means of surface water disposal not involving discharge to the public foul sewers.

For any further queries please contact us at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,



Joff Edevane
Growth Planning Lead
Business Channels