

From: Mitchell, Harry
Sent: 24 September 2020 08:45
To: Haywood, Daphney <Daphney.Haywood@havant.gov.uk>
Subject: RE: Consultee Comments for Planning Application APP/20/00508

Hi Daphney,

Sorry for the delay too many deadlines this week.

- We require tree planting lining the whole of the north of the site to help soften the development in the landscape. The clustering of tree in the corners of the site does not go far enough to soften the development.
- The proposed porous hard surfacing Type M3bp-C appears to be bound and not porous, clarity is required on how water will percolate through a bound macadam wearing course.

Kind regards,

Harry Mitchell CMLI

Chartered Landscape Architect | T: 02392 446 521 | M: 0771 8125937
Civil Engineering and Landscape Team, Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

