



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/20/00202

Our ref
PLAN-032260

Date
26/03/2020

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Two storey side extension and single storey first floor side extension over existing.
Site: APP/20/00202: - 16 Kendal close, Waterloo, PO8 8ET.

Thank you for your letter dated 06/03/2020.

It appears that the developer is intending to build over to a public surface water sewer which is crossing the site. Building over a "public sewer" is not normally permitted by Southern Water. However, under certain circumstances building over a sewer may be allowed. The conditions associated with the buildover/close to a sewer are contained in Southern Water guidance notes which are available at: [southernwater.co.uk](https://www.southernwater.co.uk). A formal application to build over to the sewer will be required to be submitted by the applicant.

In order to protect drainage apparatus, Southern Water requests that if consent is granted, a condition is attached to the planning permission; for example, the developer must advise the local authority (in consultation with Southern Water) of the measures which will be undertaken to protect the public sewers, prior to the commencement of the development.

Furthermore, it is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

Southern Water requires a formal application for any new connection to the public foul sewer to be made by the applicant or developer. We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link [southernwater.co.uk/infrastructure-charges](https://www.southernwater.co.uk/infrastructure-charges)



The disposal of surface water from this development shall follow the hierarchy within Part H3 of Building Regulations:

- a) An adequate soakaway or some other adequate infiltration system.
- b) A water course.
- c) Where neither of the above is practicable: a sewer.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: developerservices@southernwater.co.uk

Yours faithfully,



Joff Edevane
Growth Planning Lead
Business Channels