

water efficiency calculation
157 Milton Road

PRODUCT TYPE	DETAILS	PRODUCT		USE FACTOR	FIXED USE (L/P/D)	LITRES PER DAY
WC (dual flush)	Part flush volume (litres)		3	1.46	0.00	0.00
WC (dual flush)	Flow rate (litres/minute)	5.67 litre flow restrictor	5.76	2.96	0.00	8.88
Basin taps	Capacity to overflow (litres)	none	0	1.58	1.58	10.68
Bath (with shower)	Bath and shower		9	0.11	0.00	0.00
Shower (with bath)	Capacity to overflow (litres)	none	0	4.37	0.00	39.33
Bath only	Flow rate (litres/minute)	None	0	0.50	0.00	0.00
Shower only	Flow rate (litres/minute)	5.67 litre flow restrictor	5.76	5.60	0.00	0.00
Kitchen sink taps	Litres/kg dry load	Default	8.17	0.44	10.36	12.89
Washing machine	Litres/place setting	Default	1.25	2.1	0.00	17.16
Dishwasher	Litres/use	None	0	3.6	0.00	4.50
Waste disposal unit	Litres/person/day		0	3.08	0.00	0.00
Water softener						
				Total calculated use	1.00	0.00
				Contribution from greywater (l/p/d)		93.44
				Contribution from greywater (l/p/d)		0.00
				Normalisation factor		0.00
				Total water consumption (CSH)		0.91
				External water use		85.03
				Total water consumption (Part G)		5.00
						90.03

Level 3/4

Compliant

Please note: CSH = Code for Sustainable Homes

water efficiency calculation
157 Milton Road