



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/18/00918

Our ref
PLAN-028948

Date
23/07/2019

Contact
Tel 0330 303 0119

Dear Sirs,

Proposal: Request to discharge condition No/s 3 and 5 (08/05/2019).

Site: 9A, Lovedean Lane, Waterlooville, PO8 8HH.

Thank you for your letter of 11/07/2019.

Southern Water would have no objections to recommend discharge of condition 5 relating to protection of public sewer. The details are as shown on drawing provided on 11/07/2019 (no title or drawing number provided).

The construction shall be no closer than 500mm from the external edge of the public sewer and/or external edge of manhole located within the site.

The applicant is required to obtain an approval for the proposed works to ensure that the extension is built in accordance with requirements, under any of the below mentioned process:

- The construction near public sewer can be confirmed and supervised by Building Control (the location, size, depth and condition of sewer to be determined by applicant)
- The applicant may wish to apply under Declaration of Works application process (the location, size, depth and condition of sewer to be determined by applicant)
<https://developerservices.southernwater.co.uk/DeclarationOfWorks/ApplicationForm>
- The applicant may wish to apply under Build Over/ Close to Public Sewer application process (the location, size, depth and condition of sewer to be determined by Southern Water)
<https://developerservices.southernwater.co.uk/BuildOver/ApplicationForm>

Southern Water would have no comments to make with regards to other conditions being subject of consultation.



For any queries please contact us at developerservices@southernwater.co.uk

Yours Sincerely

A handwritten signature in black ink, reading "Marta Karpezo". The signature is written in a cursive, flowing style.

Marta Karpezo
Developer Services